

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST  
CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

SYSTEME CEI D'ACCEPTATION MUTUELLE DE  
CERTIFICATS D'ESSAIS DES EQUIPEMENTS  
ELECTRIQUES (IECEE) METHODE OC

**CB TEST CERTIFICATE****CERTIFICAT D'ESSAI OC**

Product  
Produit

AC-DC Power Module

Name and address of the applicant  
Nom et adresse du demandeur

ARCH ELECTRONICS CORP  
3F, No. 79, SEC 1, HSIN TAI WU RD., HSI CHIH,  
NEW TAIPEI CITY, 221  
TAIWAN

Name and address of the manufacturer  
Nom et adresse du fabricant

ARCH ELECTRONICS CORP  
3F, No. 79, SEC 1, HSIN TAI WU RD., HSI CHIH,  
NEW TAIPEI CITY, 221  
TAIWAN

Name and address of the factory  
Nom et adresse de l'usine

ARCH ELECTRONICS CORP  
3RD FL 79 SEC 1 HSIN TAI WU RD HSIN CHIN  
NEW TAIPEI 221  
TAIWAN

Note: When more than one factory, please report on page 2  
Note: Lorsque il y a plus d'une usine, veuillez utiliser la 2<sup>ème</sup> page

Additional Information on page 2  
See Page 2

Ratings and principal characteristics  
Valeurs nominales et caractéristiques principales

Trademark (if any)  
Marque de fabrique (si elle existe)



Type of Manufacturer's Testing Laboratories used  
Type de programme du laboratoire d'essais  
constructeur

See Page 2

Model / Type Ref.  
Ref. De type

Additional information (if necessary may also be  
reported on page 2)  
Les informations complémentaires (si nécessaire,,  
peuvent être indiqués sur la 2<sup>ème</sup> page

Additionally evaluated to EN 60950-1:2006 /A11:2009/A1:2010/  
A12:2011/ A2:2013; National Differences specified in the CB  
Test Report.

Additional Information on page 2

A sample of the product was tested and found  
to be in conformity with  
Un échantillon de ce produit a été essayé et a été  
considéré conforme à la

IEC 60950-1(ed.2), IEC 60950-1(ed.2);am1,  
IEC 60950-1(ed.2);am2

As shown in the Test Report Ref. No. which forms  
part of this Certificate  
Comme indiqué dans le Rapport d'essais numéro de  
référence qui constitue partie de ce Certificat

1609039-1-CB issued on 2016-11-02

This CB Test Certificate is issued by the National Certification Body  
Ce Certificat d'essai OC est établi par l'Organisme **National de Certification**



- UL (US), 333 Pfingsten Rd IL 60062, Northbrook, USA
- UL (Demko), Borupvang 5A DK-2750 Ballerup, DENMARK
- UL (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN
- UL (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

For full legal entity names see [www.ul.com/ncbnames](http://www.ul.com/ncbnames)

Date: 2016-11-03

Signature:

Jan-Erik Storgaard



Ref. Certif. No.

**DK-59139-UL**

**Model Details:**

APCN-XS, ANCN-XS, ATCN-XS,

(X can be 3.75~5.4, 9~12, 11.2~15 and 18 ~24 denotes output voltage rating)

**Factories:**

SUZHOU ARCH ELECTRONICS CO., LTD

58 YINSHENG RD, SUZHOU INDUSTRIAL, PARK, SUZHOU, JIANGSU 215126  
CHINA

**Ratings:**

Input: 100-240Vac, 0.35A, 50/60Hz,

Output rating:

For Model APCN-XS, ANCN-XS, ATCN-XS:

Where "X" can be 3.75~5.4: 3.75~5.4Vdc / 3000mA. 15W max.

Where "X" can be 9~12: 9~12Vdc / 1250mA. 15W max.

Where "X" can be 11.2~15: 11.2~15Vdc / 1000mA. 15W max.

Where "X" can be 18~24: 18~24Vdc / 625mA. 15W max.

**Additional information (if necessary)**

**Information complémentaire (si nécessaire)**



UL (US), 333 Pfingsten Rd IL 60062, Northbrook, USA



UL (Demko), Borupvang 5A DK-2750 Ballerup, DENMARK



UL (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN



UL (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

For full legal entity names see [www.ul.com/ncbnames](http://www.ul.com/ncbnames)

Date: 2016-11-03

Signature:

Jan-Erik Storgaard